

Certificate

Registration No.: PV 60026973

Page 1

Report No.: 21210769-2

License Holder:

Gällivare PhotoVoltaic AB
Företagscentrum, Box 840
98228 Gällivare
Sweden

Manufacturing Plant:

Gällivare PhotoVoltaic AB
Företagscentrum, Box 840
98228 Gällivare
Sweden

Product:

PV Module

Type:

SWEDMODULE GPV xxx, Type ID: 03
(xxx = 200 - 240 in 5 W-Steps)
SWEDMODULE GPV xxx, Type ID: 03
(xxx = 115 - 160 in 5W-Steps)
SWEDMODULE GPV xxx, Type ID: 02
(xxx = 200 - 240 in 5W-Steps)
SWEDMODULE GPV xxx, Type ID: 02
(xxx = 115 - 160 in 5W-Steps)
SWEDMODULE GPV xxx, Type ID: 01
(xxx = 145 - 185 in 5W-Steps)
SWEDMODULE GPV xxx, Type ID: 01
(xxx = 75 - 85 in 5W-Steps)

Basis:

IEC 61730-1:2004
IEC 61730-2:2004
EN 61730-1:2007
EN 61730-2:2007
"Photovoltaic (PV) module safety
qualification"

Factory Inspection
To document the consistent quality of
the product factory inspections are
performed periodically.



- Qualified, IEC 61215
- Safety tested,
IEC 61730
- Periodic Inspection

Remarks:

- IEC EN 61730 consists of part 1 (Requirements for construction) and part 2 (Requirements for testing).
- The above listed PV modules fulfil the requirements of Application Class A (Safety Class II). They may be used in PV plants at a maximum system voltage (Voc at STC) of up to 1000 VDC.
- The fire test (IEC 61730-2 / MST 23) was not performed.
- The details of the factory inspection are documented in report no. 21211246.

Conditions:

The product test is voluntarily according to technical regulations. Any change of the design, materials, components or processing may require the repetition of some of the qualification tests in order to retain type approval.

The certificate is valid until 4 June 2014.



Cologne, 23 September 2009

Dipl.-Ing. M. Adrian